

## Westampton Township Emergency Services Bureau of Fire Prevention Office of the Fire Marshal

780 Woodlane Road Westampton, New Jersey 08060 Phone (609) 267-2041 ext. 215 Fax (609) 267-3305

www.westamptonfire.org FireMarshal@westamptonfire.org

This form must be faxed or mailed to Westampton
Township Emergency Services Bureau of Fire Prevention
within 48 hours of test completion.

## **AUTOMATIC FIRE ALARM SYSTEM INSPECTION REPORT**

\*\*Only this document will be accepted by the Westampton Township Emergency Services Bureau of Fire Prevention for fire alarm testing purposes as required by the New Jersey Uniform Fire Safety Code and applicable N.F.P.A. Standards

DATE:	
TIME:	

SERVICE Name:	ORGANIZATION		PROPERTY NAME (USER) Name:	
Address:		<del></del>	Address:	
Representa	ative:		Owner Contact:	
License #:			Telephone:	
Telephone				
MONITOR	ING ENTITY		APPROVING AGENCY	
Contact:			Contact:	
Telephone	:		Telephone:	
Monitoring	Account Ref. #:			
	NSMISSION		SERVICE	
□ McCul		Reverse priority	,	□ Semiannually
□ Multipl		□ RF	,	□ Annually
<ul><li>Digital</li></ul>			□ Quarterly	
□ Other	(Specify)		□ Other (Specify)	
Control Un	it Manufacturer:		Model #:	
Circuit Styl				_
Number of Software R				
	System Had Any Servic	ea Performed:		
	•	nfiguration Was Revised:		
Qty	Circuit Style	ALARM-INITIATING DEVICES AN	D CIRCUIT INFORMATION  Qty Circuit Style	
Qty	Circuit Style	Manual Fire Alarm Boxes	Gircuit Style	Heat Detectors
		Ion Detectors	-	Waterflow Switches
		Photo Detectors		Supervisory Switches
		Duct Detectors		Other (Specify)
Alarm verif	ication feature is disabl	ed: enabled:		
		ALARM NOTIFICATION APPLIANCES	S AND CIRCUIT INFORMATION	
Qty	Circuit Style	ALAKII NOTII TOATION AIT LIANOLO	Qty Circuit Style	
۵.,	on our ory.o	Bells	ary chican cryst	Strobes
		Horns		Speakers
		Chimes		Other (Specify)
Number of	alarm notification appli	ance circuits:		
	s monitored for integrity			
		SUPERVISORY SIGNAL-INITIATING DEVI		
Qty	Circuit Style		Qty Circuit Style	
		Building Temp		Fire Pump Power
		Site Water Temp		Fire Pump Running
		Site Water Level		Fire Pump Auto Position
		Generator in Auto Position		Fire Pump Trouble
		Generator or Controller Trouble		Fire Pump Controller Troubl
		Switch Transfer		Other: (Specify)
		Generator Engine Running		
CICNALIN	C LINE CIDCUITS			
	G LINE CIRCUITS  nd style of signaling line	e circuits connected to system (see NFPA 72,	Table 6.6.1):	
Quantity:		Style(s):		

SYSTEM POWER SUPPLIES	3						
(a) Primary (Main): Nominal V				Amps			
Overcurrent Protection: T			P	Amps			
Location (of Primary Supp							
Disconnecting Means Loc	cation						
(b) Secondary (Standby):	_						
Storage Battery: Amp-Hr	Rating						
Calculated capacity in		Amp-Hrs to opera	ate system fo	orh	nours		
Engine-driven generator	dedicated to fire alarm s	system:	_				
Location of fuel storage:							
TYPE BATTERY							
□ Dry Cell □ Nick	el-Cadmium	Sealed Lead-Acid	d c	Lead-Acid			
□ Other: (Specify)							
(c) Emergency or standby sy	rstem used as a backup	to primary power s	upply, instea	ad of using a seconda	ry power supply:		
	Emergency system des						
	Legally required standb	•					
	Optional standby syste	m described in NFP	A 70, Article	702 which also meet	s the performance red	quirements of	f
	Article 700 or 701						
		PRIOR TO	ANY TEST	ING			
NOTIFICATIONS ARE MADE	Ē	Yes	No	Who	т	ime	
Monitoring Entity							
Building Occupants							
Building Management							
Other (Specify)							
AHJ Notified of Any Impairme	ents						
				-			
		SYSTEMS TEST	'S AND INSF				
TYPE	Visual	Functional		Comments			
Control Unit		_					
Interface Equipment							
Lamps/LEDs Fuses							
Primary Power Supply				-			
Trouble Signals				-			
Disconnect Switches							
Ground-Fault Monitoring							
	_	_		-			
SECONDARY POWER							
TYPE	Visual	Functional		Comments			
Battery Condition							
Load Voltage							
Dicharge Test							
Charger Test							
Specific Gravity	\(\frac{1}{2} = \cdot \frac{1}{2} \)			0			
TRANSIENT SUPPRESSOR	Visual	Functional		Comments			
TRANSIENT SUPPRESSUR	S 🗆						
REMOTE ANUNCIATORS							
NOTIFICATION APPLIANCE	e						
Audible	<b>J</b>						
Visible				-			
Speakers							
Voice Clarity							
research,							
				ESTS AND INSPECT	TIONS	_	
	evice Vis		nctional	Factory		Pass	Fail
	Type Che		Test	Setting	Measured Settin	_	
				-			
		=	_				u
Comments:							

EMERGENCY COMMUNICATIONS EQUIPMENT	Visual	Functional	Comments
Phone Set			
Phone Jacks			
Off-Hook Indicator			
Amplifier(s)			
Tone Generator(s)			
Call-in Signal			
System Performance			
COMBINATION SYSTEMS	Visual	Device Operation	Simulated Operation
Fire Extinguisher Monitoring Device/System			
Carbon Monoxide Detector/System			
(Specify)			
INTERFACE EQUIPMENT			
(Specify)			
(Specify)			
(Specify)			
SPECIAL HAZARD SYSTEMS	_	-	_
(Specify)			
(Specify)			
Special Procedures:			
Comments:			
SUPERVISING STATION MONITORING	Yes	No Time	Comments
Alarm Signal			
Alarm Restoration			_
Trouble Signal			_
Trouble Signal Restoration			
Supervisory Signal Supervisory Restoration			
NOTIFICATION THAT TESTING IS COMPLETE		w	ho Time
Building Management			
Monitoring Agency			
Building Occupants			
Other (Specify)			
The following did not operate correctly/deficiencies noted:			
System restored to normal operation: Date:	Time	e:	
THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICA			
Name of Inspector:Signature:	Date:	Т	ime:
Name of Owner or Representative:	Date:	Т	ime:
Signature:	_		-
DIGITALUI E.			